



Board of Alderman Request for Action

MEETING DATE: 5/17/2021

DEPARTMENT: Public Works

AGENDA ITEM: Approve Resolution 1067 authorizing Menke Excavation to complete sewer main repairs in the amount of \$11,147.50

REQUESTED BOARD ACTION:

A motion to approve Resolution 1067, authorizing sewer main repairs.

SUMMARY:

In 1995, a 4" force main was installed to service the First Park Subdivision. When the couple existing business and the Fire Department located along Park Drive, individual services to an 8" main on Highway 169 were installed rather than connecting to the force man for the industrial park. The 4" force main has never been in service.

CPC is currently progressing with the construction of their new facility in First Park. They connected to the 4" force main, however the force main does not hold pressure. City staff excavated where we believed the leak to be but cannot locate the leak. Since the line was installed in 1995, there is no tracer wire. We believe the main lies beneath the concreted area of the carwash. There are also a number of other utilities in the area.

The plan would be to move away from the other utilities and bore a new line under the street. This can be done relatively easily and the new line would have no joints. We would then connect to the main that runs along Highway 169.

CPC is already tied in and this work needs to be completed to provide the service. Menke Excavation can do this work and has successfully completed many projects for the City.

PREVIOUS ACTION:

POLICY ISSUE:

Maintaining infrastructure

FINANCIAL CONSIDERATIONS:

Sufficient funds are in the Utilities operating budget to fund this project.

ATTACHMENTS:

- ☐ Ordinance
- ☒ Resolution
- ☐ Staff Report

- ☐ Contract
- ☐ Plans
- ☐ Minutes

☒ Other: quote

RESOLUTION 1067

A RESOLUTION AUTHORIZING MENKE EXCAVATING TO COMPLETE SEWER MAIN REPAIRS IN THE AMOUNT OF \$11,147.50

WHEREAS, CPC of Missouri is constructing a facility in the First Park Subdivision and requires sanitary sewer services; and

WHEREAS, the existing force main is not serviceable; and

WHEREAS, time is of the essence to provide sanitary sewer service to this facility; and

WHEREAS, Menke Excavation has provided a bid to install a new force main in the amount of \$11,147.50.

**NOW, THEREFORE, BE IT RESOLVED BY THE BOARD OF ALDERMEN OF
THE CITY OF SMITHVILLE, MISSOURI:**

THAT Menke Excavating is authorized to complete and install a new force main in First Park in an amount of \$11,147.50

PASSED AND ADOPTED by the Board of Aldermen and **APPROVED** by the Mayor of the City of Smithville, Missouri, this 17th day of May, 2022.

Damien Boley, Mayor

ATTEST:

Linda Drummond, City Clerk

From: Steve Menke dba <stevemenke@centurylink.net>

Sent: Sunday, May 1, 2022 8:56 PM

To: Bob Lemley <BLemley@smithvillemo.org>

Cc: Forest Watkins <forest.watkins@yahoo.com>; Chuck Soules <csoules@smithvillemo.org>

Subject: Raintree Lane and Park Drive estimates

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Bob

Listed below are the two bids you and Dave wanted. Let me know if you have any questions or concerns.

1. Park Drive

230 feet of 4" forced sewer main bored at Park Drive \$11,147.50

Boring will be subbed to Brad Lincoln or John Marshal.

Both bids include tracer wire and include all material and labor.

Estimate expires 5-25-22

Rock excavation, rock trenching, rock boring at time and material.

Utility relocation at time and material

Pipe bedding at 7.86 LF

Thank you for another opportunity to work for the City of Smithville.

MENKE EXCAVATING LLC

Steve Menke, Owner

stevemenke@centurylink.net

(816) 214-7352

"Moving earth and water with Precision"