

## **Board of Aldermen Request for Action**

MEETING DATE: 7/18/2023 DEPARTMENT: Public Works

**AGENDA ITEM:** Resolution 1240, authorizing the emergency repair of the aerator at the

wastewater treatment plant.

## **REQUESTED BOARD ACTION:**

A motion to approve Resolution 1240, authorizing emergency repair of the aerator in digestor #2 at the wastewater treatment plant from Mid-America Pump in the amount of \$39,569.05.

### **SUMMARY:**

At the June 6 Board of Alderman meeting, staff reported that the aerator in Digestor #2 was not working properly. Staff noticed the breakers providing power were tripping causing the aerator not to function. Staff contacted Mid – America Pump to pull the motor and troubleshoot the cause. It was determined that the stator and windings of the motor were blown causing a power failure.

The City recently completed the installation of a new floating aerator in Digestor #1. We explored the option of replacing the entire motor (versus repairing) with a similar motor that drives the new aerator. We could have also then purchased a replacement motor to have as back up. The unit is too old (originally installed in 2007) and has different horsepower and a replacement motor for this unit is no longer available. Repair / rebuilding the existing unit, at this time, is the only option. The City will need to plan to replace this aerator in the next several years.



Lead time for some of the parts and windings was 30 weeks out. We reported at the Board meeting on June 6 that we would need to proceed as soon as we had a proposal

from Mid-America. With this unit down, amr plant. Staff is having to haul more sludge ar ammonia levels down.	monia levels are higher than normal at the nd land apply more frequently trying to keep			
PREVIOUS ACTION: Reported June 6, 2023				
POLICY ISSUE: Facility / infrastructure maintenance				
FINANCIAL CONSIDERATIONS: The 2023 CWWS maintenance budget has sufficient funds for this expense.				
ATTACHMENTS:				
□ Ordinance	☐ Contract			
□ Resolution	☐ Plans			
☐ Staff Report	☐ Minutes			
☑ Other: Proposal				

#### **RESOLUTION 1240**

# A RESOLUTION AUTHORIZING EMERGENCY REPAIR OF THE AERATOR IN DIGESTOR #2 AT THE WASTEWATER TREATMENT PLANT

**WHEREAS**, the City of Smithville operates a wastewater treatment plant to treat the City's sanitary sewage; and

**WHEREAS**, the stator in the motor that runs the aerator in Digestor #2 has failed causing power issues at the wastewater treatment plant; and

WHEREAS, repair of the motor and aerator is necessary and essential for the operation of the plant; and

**WHEREAS**, Mid-America Pump has provided a proposal in the amount of \$39,569.05 and can make the repairs to the equipment.

NOW THEREFORE BE IT RESOLVED BY THE BOARD OF ALDERMEN OF THE CITY OF SMITHVILLE, MISSOURI, AS FOLLOWS:

**THAT** the Board authorizes the emergency repair proposal of the motor and aerator from Mid-America Pump in an amount of \$39,569.05

**PASSED AND ADOPTED** by the Board of Aldermen and **APPROVED** by the Mayor of the City of Smithville, Missouri, the 18<sup>th</sup> day of July, 2023.

Damien Boley, Mayor	
ATTEST:	
Linda Drummond, City Clerk	



5600 Inland Drive Kansas City, Kansas 66106 Phone 913-287-3900 Fax 913-287-6641

# **REPAIR PROPOSAL**

SKP:	7811		
Customer PO #:		Repair Estimate:	\$39,569.05
Prepaired By #:	Brad Saul	Replacement Price:	
Date:	6/22/2023	Estimated Delivery:	

	Customer Information		
Bill To:	Contact Info:		Ship To:
Company Name: City of Smithville	First Name: Bob	Company:	
Address: 107 W. Main Street	Last Name: Lemley	Address:	
City: Smithville	Phone: (816) 532-0070	City:	
State/Zip Code: Missouri 64089-	Fax: (816) 532-8331	State/Zip Code:	
Description of Problem		Pump I	nformation
This is for repair/replacement of the aerator at t	he WWTP that was causing the whole plant	Pump Make:	Aqua-Lator
to dim.		Model:	10011-SF
		Style:	Floating Aerator
		Pump RPM:	
		Motor RPM:	885
			Seal
Repair Description			Packing
Repair proposal to include:		Serial No:	
-stator rewind with heaters		HP:	100
-new motor bearings -new lip seals		Voltage:	460
-new power and sensor cables		Coupling:	
-new portable entry connections for the cables -new pecker head gasket			
-new bushing deflector		Application	n Information
-new debris deflector -new slinger		Pumpage:	
-new low trajectory difusser 48" diameter		Head:	
Labor to unwire and remove unit from the basin reused, assemble and test.	; teardown and inspect, clean up parts being	Flow:	
Labor to install unit and new power and heater cables, test run and set rotation.		Temp:	
Truck and MLS charges		Viscosity:	
**Lead time on rewind is 3-4 weeks, lead time of	on Evoqua parts is 6-7 weeks**	SpecificGravity:	
**Does not include FREIGHT or anything else not	ot listed above, please see terms and	. ,	
conditions**	or instead above, please see terms and	☐ Hazardous	☐ Rotation Left
		☐ MSDS	☐ Rotation Right
		Terms an	d Conditions
		1 Freight Charges N 2 Taxes Not Include	
		3 Expedite Fees Not	Included
		4 Payment Terms - I 5 Warranty Period -	
		6 Proposal Vaild for	30 Days
			on/Field Service Hours/MLS uipment is Not Repaired or
		Replaced through M	